

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**


No. F6/DFS/MS/School/SZ/2022/312

Dated: 25/03/2022

FIRE SAFETY CERTIFICATE

Certified that **Bajaj Public School** located at **Street No.- 04, Prem Nagar, New Delhi- 110008**, running at ground and second floor of a building comprised of basement, ground plus two upper floors was granted Fire Safety Certificate by this department vide letter No. F.6/DFS/MS/School/SZ/2018/842 dated 25.04.2018. The school building was re-inspected by the officer concerned of this department on 22.03.2022 in presence of Shri Shrey Bajaj, Chairman of the school and found that the School have deemed complied with the fire prevention and fire safety requirements in accordance with the Directorate of Education circular No. F.6/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 and that the school building (**ground plus two upper floor**) is fit for occupancy class "Educational" with effect from 25/03/2022 for a period of three years, subject to compliance of the under mentioned conditions.

Issued on 25/03/2022 at New Delhi by.



(Sunil Chaudhary)
Dy. Chief Fire Officer (SZ)
Delhi Fire Service

Copy to: -

1. The Chairman, Bajaj Public School, Street No.- 04, Prem Nagar, New Delhi- 08.
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.

Conditions for the Validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in.
8. All the means of escapes /exits shall not be locked/blocked at any time for safe evacuation of the occupants in case of emergency.