

MUNICIPAL CORPORATION OF DELHI
(Office of the Deputy Health Officer)
Public Health Department: Karol Bagh Zone
Anand Parbat, New Delhi – 110005
Phone No. 011-25818502,
E-mail ID No. dhokbz@gmail.com

No. DHO/KBZ/2023/ 132

Dated: 25-05-2023

School Health Certificate

To

The Principal
Bajaj Public School
Street no.4, Prem Nagar
New Delhi - 110008


Shift: Timing 08:00 am to 01:30 pm

No., of Students: Total - 700

No. of Staff Members Working in School - 20

1. That the accommodation provided for in class rooms as calculated.
- Floor space in the class room is sufficient.
2. That the all rooms are well ventilated white washed and well lighted.
3. That the class rooms are kept neat and clean.
4. That the building, class rooms are in good condition.
5. That the drinking water is wholesome/potable.
6. That the first aid box is also arranged in proper manner.
7. That the latrine arrangement is flush.
8. The no. of Toilet - 23
9. The premises found under sanitary and hygiene from Health point of view.

Validity : This Certificate is valid for One year from the date of issue.



Deputy Health Officer
Karol Bagh Zone



Deputy Health Officer
Karol Bagh Zone, MCD Delhi



DELHI JAL BOARD: GNCTD
CENTRAL LABORATORY WTP WAZIRABAD, DELHI-54



THE REPORT RELATES TO THE
PARTICULAR SAMPLE ONLY

TEST REPORT

Sample ID	Ref.No. D.J.B/DTQC/Wzd./2022/Paid-47-48		
Location /Address of Sample	Bajaj Public School Street No.4 Prem Nagar Delhi-08		
Name of Work	--		
Reference No.	BPS/F/5/2022	Ref. Letter Date	18.05.2022
Challan No.	88	Challan Date	08.06.2022
Sample Collection date	11.06.2022	Analysis date	11.06.2022
Any other Information	--	Reporting date	13.06.2022

TEST RESULTS

S.N.	Parameters	Unit	As per the IS 10500		Inlet	Outlet
			Desirable limit	Permissible limit		
1	Turbidity	NTU	1	5	1.97	1.34
2	pH Value	--	6.5-8.5	No relaxation	7.37	7.18
3	Colour	Pt-Co	5	15	Clear	Clear
4	Odour	Agreeable	Agreeable	Agreeable	Agreeable	Agreeable
5	Electrical Conductivity	$\mu\text{s/cm}$	-	-	628	280
6	Total Dissolved Solids	Mg/l	500	2000	314	140
7	Total Alkalinity as CaCO_3	Mg/l	200	600	114	72
8	Total Hardness as CaCO_3	Mg/l	200	600	154	108
9	Calcium as Ca	Mg/l	75	200	37.6	28
10	Magnesium as Mg	Mg/l	30	100	14.40	9.12
11	Ammonical-Nitrogen	Mg/l	NIL	0.5	ND	ND
12	Nitrate	Mg/l	--	45	9.37	4.78
13	Chlorides as Cl	Mg/l	250	1000	84	28
14	Fluoride as F	Mg/l	1.0	1.5	0.49	0.28
15	Sulphate as SO_4	Mg/l	200	400	39.4	13.9
16	T. Iron	Mg/l	--	1.0	0.12	0.06
17	Residual Chlorine	Mg/l	0.2	1.0	1.0	ND
18	COLIFORM COUNT AT 37 ^o C	MPN/100 ml	Absent	--	0	0

.....End of Report.....

Remarks : On the basis of above tested parameters, above water samples conform drinking Water Specification IS-10500 & can be considered fit for drinking purpose.

ACWA

CHEMIST

A/CHEMIST
Y

Asstt. Chief Water Analyst
D.J.B. (GNCTD) of Delhi
Water Works, Wazirabad